



Government Of West Bengal
Office Of The Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo no.:DY.DFS/1075/2013

Date: 23-03-2021

From:

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

To: Bengal College of Education

Plot No-429,431, J.L.No.-48, Khatian No-782, Vill-Dakshin Gram, P.O-Palsonda, P.S-Nabagram, Dist-Murshidabad

Sub: The Fire Safety Certificate of an Existing G+2 Storied Building under group Educational at the premises - Plot No-429,431, J.L.No.-48, Khatian No-782, Vill-Dakshin Gram, P.O-Palsonda, P.S-Nabagram, Dist-Murshidabad. Which Name in Style "Bengal College of Education"

This is in reference to your application no. 0125189210900043 dated 02-03-2021 regarding the The Fire Safety Certificate of an Existing G+2 Storied Building under group Educational at the premises - Plot No-429,431, J.L.No.-48, Khatian No-782, Vill-Dakshin Gram, P.O-Palsonda, P.S-Nabagram, Dist-Murshidabad. Which Name in Style "Bengal College of Education"

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
6. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
7. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
8. First aid fire fighting system shall be provided as per I.S specification.
9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189210900043.

Page : 1

equipment's installed in the building to keep them in perfectly good working conditions at all times.

10. Fire License shall have to be obtained for storing and processing with highly combustible articles.

11. The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Digitally signed by BAM
KUMAR CHOWDHURY
Date: 2021.03.23 16:52:11 IST

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

Memo No.: DY.DFS/1075/20